Evaluation and Certification ABAR-W375-00-00013

This ABAR proposes the modifications of standards for Process Safety Management currently contained in the SRD, QAPIP, and ISMP. Specifically, the changes include the following:

Revise the definition of Safety Design Class in SRD SC 1.0-8 and 2.0-2, QAPIP Section 1.2.1, and ISMP Section 12 from ERPG-2 to workers or the public to ERPG-2 to the public, ERPG-3 to the co-located worker, or a single worker fatality or hospitalization of 3 or more workers. Provide for use of TEEL values as substitute criteria in cases where no ERPG value has been published.

Replace ISMP with SRD Appendix A as an implementing standard for SRD SC 1.0-1, 3.1-1, -2, -3, -4,-5, -8.

Remove references to 29 CFR 1910.119 and/or 40 CFR 68 as regulatory bases in SRD SC 1.0-1, 3.1-1, -2, -3, -5, -6, -7, -8, 4.0-2, 4.5-23, 6.0-1, -5, 7.1-1, -2, 7.2-3, -3, -5, -6, -7, -8, 7.3-7, -10, -11, 7.6-2, -4, 7.7-1, -2, -3, 7.8-1, -2, -5, 9.1-7, and ISMP Sections 1.3.16, 1.3.17, 3.10, 5.0, 5.6.8, 7.2, and 9.2.

Delete SRD Section 9.3

Revise SRD SC 3.1-1 to specify chemical hazards must be included in the PHA.

Revise SRD SC 3.1-2 to allow compilation of process safety information appropriate to the level of design, to support the PHA.

Revise the update frequency for PHA specified in SRD SC 3.1-7, and ISMP Sections 5.6.2 and 9.2 from once every 5 years to annual.

Revise the seismic design criteria in SRD SC 4.1-3 and 4.1-4, and ISMP Section 1.3.10 for SSC's designated SDC on the basis of chemical consequences from SC-I/II to SC-III.

Revise the chemical concentration limits specified in SRD SC 4.3-7for control room habitability from ERPG-2 to the values specified in 29 CFR 1910.120, and add 29 CFR 1910.120 to the list of regulatory bases.

Include chemical hazards in the definition of USQ specified in SRD SC 7.4-1, and ISMP Section 3.16.4.

Revise the scope of the Hazards Identification specified in SRD Appendix A, Section 4.3.1 to include chemical hazards.

Revise the discussion of control room habitability in SRD Appendix A, Section 5, and ISMP Section 1.3.7 and 8 to be consistent with changes made to SRD SC 4.3-7.

Tables 1 and 2, below, specify each proposed change and provide the reason for the change. The evaluation that concludes the proposed changes provide adequate safety, comply with all applicable laws and regulations, and conform to top-level safety standards is provided in the text following the tables. Although the text pertains specifically to the changes proposed for the SRD, the rationale applies equally to the other two documents, the ISMP and the QAPIP. These documents will be revised at the same time the SRD is revised, via the same ABAR.

Table 1. Changes to the SRD Requirements for the PSM Program

Table 1. Changes to the SRD Requirements for the PSM Program		
Proposed Change	Reason for Change	
SC 1.0-1 Replace ISMP Chapter 5.0 and	Appendix A should replace the ISMP as	
Section 4.1 with SRD Appendix A as an	the implementing standard because	
implementing standard. Delete 40 CFR 68	Appendix A provides more definitive	
and 29 CFR 1910.119 as regulatory basis	requirements pertaining to process hazards	
documents.	analysis. 29 CFR 1910.119 and 40 CFR 68	
	should be deleted because WTP is currently	
	not required to implement the requirements	
	of either of these rules. None of the	
	chemicals contained in the facility exceed	
	the threshold quantities listed in the rules.	
SC 1.0-8 Revise the definition of Safety	The threshold value for co-located workers	
Design Class to show ERPG-3	should be increased to be consistent with	
concentrations for the co-located worker,	recommended usage of the ERPG's for	
and concentrations that could reasonably be	emergency planning. The threshold value	
expected to results in either a single worker	for facility workers should be increased to	
fatality or require in-patient hospitalization	be consistent with OSHA requirements	
of 3 workers or more. Definition of SDC	regarding the immediate reporting of	
for members of the public remains	serious accidents. Several chemicals	
unchanged. Provide for use of TEEL	planned for use at WTP do not have ERPG	
concentrations where no ERPG has been	data, therefore an equivalent value is	
published.	needed and TEEL will be itilized.	
SC 2.0-2 See SC 1.0-8, above.	SC 2.0-2 See SC 1.0-8, above.	
SC 3.1-1 Revise the criterion to clarify that	The text of the standard should be revised	
the process hazards analysis must consider	for clarification and consistency with the	
both radiological and chemical hazards.	proposed implementing standard. This	
Replace the ISMP with Appendix A of the	standard requires that both chemical and	
SRD as the implementing standard.	radiological hazards be evaluated in the	
Remove reference to 29 CFR 1910.119 and	standards identification process. Appendix	
40 CFR 68 as the regulatory basis.	A should replace the ISMP as the	
	implementing standard because Appendix	
	A provides more definitive requirements	
	pertaining to process hazards analysis. 29	
	CFR 1910.119 and 40 CFR 68 should be	
	deleted because WTP is currently not	
	required to implement the requirements of	
	either of these rules. None of the chemicals	
	contained in the facility exceed the	
SC 2.1.2 Paying tayt to magain association	threshold quantities listed in the rules.	
SC 3.1-2 Revise text to require compilation	Requiring acquisition of all process safety	
of process safety information appropriate to	information prior to implementation of the	
the stage of design, to support the PHA.	Hazards Identification step of the ISM	
Replace the ISMP with Appendix A of the	process often causes undue delays in	
SRD as the implementing standard.	standards identification. Appendix A	

Remove reference to 29 CFR 1910.119 and	should replace the ISMP as the
40 CFR 68 as the regulatory basis.	implementing standard because Appendix
	A provides more definitive requirements
	pertaining to process safety information.
	29 CFR 1910.119 and 40 CFR 68 should
	be deleted because WTP is currently not
	required to implement the requirements of
	either of these rules. None of the chemicals
	contained in the facility exceed the
	threshold quantities listed in the rules.
SC 3.1-3 Replace the ISMP with Appendix	Appendix A should replace the ISMP as
A of the SRD as the implementing	the implementing standard because
standard. Remove reference to 29 CFR	Appendix A provides more definitive
1910.119 and 40 CFR 68 as the regulatory	requirements pertaining to process hazards
basis.	analysis. 29 CFR 1910.119 and 40 CFR 68
	should be deleted because WTP is currently
	not required to implement the requirements
	of either of these rules. None of the
	chemicals contained in the facility exceed
SC 2.1.4 Donlars the ISMD with Amandia	the threshold quantities listed in the rules.
SC 3.1-4 Replace the ISMP with Appendix	Appendix A should replace the ISMP as
A of the SRD as the implementing standard.	the implementing standard because Appendix A provides more definitive
Standard.	requirements pertaining to process hazards
	analysis.
SC 3.1-5 Replace the ISMP with Appendix	Appendix A should replace the ISMP as
A of the SRD as the implementing	the implementing standard because
standard. Remove reference to 29 CFR	Appendix A provides more definitive
1910.119 as the regulatory basis.	requirements pertaining to employee
	participation in the process hazards
	analysis. 29 CFR 1910.119 should be
	deleted because WTP is currently not
	required to implement the requirements of
	this rule. None of the chemicals contained
	in the facility exceed the threshold
	quantities listed in the rule.
SC 3.1-6 Remove reference to 29 CFR	29 CFR 1910.119 and 40 CFR 68 should
1910.119 and 40 CFR 68 as the regulatory	be deleted because WTP is currently not
basis.	required to implement the requirements of
	either of these rules. None of the chemicals
	contained in the facility exceed the
2.1.7 Daviga DIIA undata internal to anno	threshold quantities listed in the rules.
3.1-7 Revise PHA update interval to once	The interval for revision of the chemical
every year. Remove reference to 29 CFR	portions of the PHA should be consistent with the interval for revision of the
1910.119 and 40 CFR 68 as the regulatory	
basis.	radiological portion, since the same PHA

	covers both hazard types. 29 CFR
	1910.119 and 40 CFR 68 should be deleted
	because WTP is currently not required to
	implement the requirements of either of
	these rules. None of the chemicals
	contained in the facility exceed the
	threshold quantities listed in the rules.
3.1-8 Replace the ISMP with Appendix A	Appendix A should replace the ISMP as
of the SRD as the implementing standard.	the implementing standard because
Remove reference to 29 CFR 1910.119 and	Appendix A provides more definitive
40 CFR 68 as the regulatory basis.	requirements pertaining to the disposition
l a comment of the co	of process hazards analysis results (ie.,
	incorporate them into the SARs). 29 CFR
	1910.119 and 40 CFR 68 should be deleted
	because WTP is currently not required to
	implement the requirements of either of
	these rules. None of the chemicals
	contained in the facility exceed the
	threshold quantities listed in the rules.
4.0-2 Remove reference to 29 CFR	29 CFR 1910.119 should be deleted
1910.119 as the regulatory basis.	because WTP is currently not required to
į ,	implement the requirements of this rule.
	None of the chemicals contained in the
	facility exceed the threshold quantities
	listed in the rule.
4.1-3 Revise the seismic standard to	The designation of SC-I and II is intended
specify SC-III for chemical systems.	to address hazards that are significantly
	larger at WTP than they are in the non-
	nuclear industry (ie., the large radioactive
	material inventories). Therefore a seismic
	design standard needed to be developed
	specifically for the nuclear industry. This
	standard was not intended to be applied to
	the chemical hazards at WTP. The
	chemical hazards routinely encountered in
	the chemical industry are significantly
	larger both in toxicity and amounts than
	those present at WTP. These non-nuclear
	industries have developed seismic design
	requirements to deal with these chemical
	hazards. These requirements are embodied
	in the Uniform Building Code, which is
	implemented at WTP as Seismic Category
	III, as augmented.
SC 4.1-4 Revise to include chemical	See reason for revisions to SC 4.1-3 above.
hazards.	I

SC 4.3-7 Revise to require that worker exposure not exceed concentrations specified in 29 CFR 1910.120.	The ERPG-2 value is inappropriate for purposes of control room habitability. The correct standard should be the standards for emergency exposures specified in 29 CFR 1910.120.
SC 4.5-23 Remove reference to 29 CFR 1910.119 as the regulatory basis.	29 CFR 1910.119 should be deleted because WTP is currently not required to implement the requirements of this rule. None of the chemicals contained in the facility exceed the threshold quantities listed in the rule.
SC 6.0-1 Remove reference to 29 CFR 1910.119 as the regulatory basis.	29 CFR 1910.119 should be deleted because WTP is currently not required to implement the requirements of this rule. None of the chemicals contained in the facility exceed the threshold quantities listed in the rule.
SC 6.0-5 Remove reference to 29 CFR 1910.119 as the regulatory basis.	29 CFR 1910.119 should be deleted because WTP is currently not required to implement the requirements of this rule. None of the chemicals contained in the facility exceed the threshold quantities listed in the rule.
SC 7.1-1 and –2 Remove reference to 29 CFR 1910.119 and 40 CFR 68 as the regulatory basis.	29 CFR 1910.119 and 40 CFR 68 should be deleted because WTP is currently not required to implement the requirements of either of these rules. None of the chemicals contained in the facility exceed the threshold quantities listed in the rules.
SC 7.2-3 through 7.2-8 Remove reference to 29 CFR 1910.119 and 40 CFR 68 as the regulatory basis.	29 CFR 1910.119 and 40 CFR 68 should be deleted because WTP is currently not required to implement the requirements of either of these rules. None of the chemicals contained in the facility exceed the threshold quantities listed in the rules.
SC 7.3-7 and –11 Remove reference to 29 CFR 1910.119 as the regulatory basis.	29 CFR 1910.119 should be deleted because WTP is currently not required to implement the requirements of this rule. None of the chemicals contained in the facility exceed the threshold quantities listed in the rule.
SC 7.3-10 Remove reference to 29 CFR 1910.119 and 40 CFR 68 as the regulatory basis.	29 CFR 1910.119 and 40 CFR 68 should be deleted because WTP is currently not required to implement the requirements of either of these rules. None of the chemicals contained in the facility exceed the

	threshold quantities listed in the rules.
SC 7.4-1 Revise text to include chemical	The WTP has elected to manage
hazards in the USQ process.	radiological, nuclear and process safety as
The second secon	a single integrated program. Therefore, the
	existing USQ program has been modified
	to implement the PSM aspect of
	Management of Change.
SC 7.6-2 Remove reference to 29 CFR	29 CFR 1910.119 should be deleted
1910.119 as the regulatory basis.	because WTP is currently not required to
1910.119 us the legalatory busis.	implement the requirements of this rule.
	None of the chemicals contained in the
	facility exceed the threshold quantities
	listed in the rule.
SC 7.6-4 Remove reference to 29 CFR	29 CFR 1910.119 and 40 CFR 68 should
1910.119 and 40 CFR 68 as the regulatory	be deleted because WTP is currently not
basis.	required to implement the requirements of
	either of these rules. None of the chemicals
	contained in the facility exceed the
CC 7.7.1. 2. 1. 2.D	threshold quantities listed in the rules.
SC 7.7-1, -2, and -3 Remove reference to	29 CFR 1910.119 and 40 CFR 68 should
29 CFR 1910.119 and 40 CFR 68 as the	be deleted because WTP is currently not
regulatory basis.	required to implement the requirements of
	either of these rules. None of the chemicals
	contained in the facility exceed the
	threshold quantities listed in the rules.
SC 7.8-1, and –5 Remove reference to 40	40 CFR 68 should be deleted because WTP
CFR 68 as the regulatory basis.	is currently not required to implement the
	requirements of this rule. None of the
	chemicals contained in the facility exceed
	the threshold quantities listed in the rule.
SC 7.8-2 Remove reference to 29 CFR	29 CFR 1910.119 and 40 CFR 68 should
1910.119 and 40 CFR 68 as the regulatory	be deleted because WTP is currently not
basis.	required to implement the requirements of
	either of these rules. None of the chemicals
	contained in the facility exceed the
	threshold quantities listed in the rules.
SC 9.1-7 Remove reference to 40 CFR 68	40 CFR 68 should be deleted because WTP
as the regulatory basis.	is currently not required to implement the
	requirements of this rule. None of the
	chemicals contained in the facility exceed
	the threshold quantities listed in the rule.
Section 9.3 Delete the entire chapter.	WTP is currently not required to
	implement the requirements of 40 CFR 68.
	None of the chemicals contained in the
	facility exceed the threshold quantities
	listed in the rule.

Appendix A, Section 4.3.1 Revise to be	The ISM process requires that chemical
more specific about the scope of the	hazards be included as potential initiators
chemical hazards assessment.	of radiological events, as well as hazards in
	their own right.
Appendix A, Section 5.0 Revise	Revision is needed to be consistent with
discussion of ERPG concentrations.	revisions made to SC 1.0-8.

Table 2. Changes to the QAPIP and ISMP

Proposed Change	Passon for Change
Proposed Change	Reason for Change
QAPIP Section 1.2.1 Revise definition of	Revision is needed to conform to SRD
Safety Design Class.	definition.
ISMP Section 1.3.7 Delete references to	Revision is needed to conform to
ERPG-2 and revise specification for	corresponding changes to the SRD.
control room habitability.	
ISMP Section 1.3.8 Delete references to	Revision is needed to conform to
ERPG-2 and revise specification for	corresponding changes to the SRD.
control room habitability	
ISMP Section 1.3.10 Exclude chemical	Revision is needed to conform to SRD
safety SSC's from SC-I/II criteria.	allocation of seismic design requirements
	for chemical safety.
ISMP Section 1.3.16 Delete reference to 29	Requirements of 29 CFR 1910.119 do not
CFR 1910.119.	apply to WTP, since there are no threshold
	chemicals present.
ISMP Section 1.3.17 Delete reference to 29	Requirements of 29 CFR 1910.119 do not
CFR 1910.119.	apply to WTP, since there are no threshold
	chemicals present.
ISMP Section 3.10 Delete reference to 29	Requirements of 29 CFR 1910.119 and 40
CFR 1910.119 and 40 CFR 68.	CFR 68 do not apply to WTP, since there
CTR 1910.119 and 10 CTR 00.	are no threshold chemicals present.
ISMP Section 3.16.4 Include chemical	Revision is needed to conform to SRD
hazards in definition of USQ.	definition.
	Revision is needed to conform to SRD
ISMP Section 5.6.2 Revise update	
requirements for HAR to annually.	requirement to update PHA.
ISMP Sections 5.0 and 5.6.8 Delete	Requirements of 29 CFR 1910.119 and 40
reference to 40 CFR 68.	CFR 68 do not apply to WTP, since there
	are no threshold chemicals present
ISMP Section 7.2 Delete reference to 29	Requirements of 29 CFR 1910.119 do not
CFR 1910.119	apply to WTP, since there are no threshold
	chemicals present
ISMP Section 9.2 Revise update	Revision is needed to conform to SRD
requirements for the HAR and delete	requirement to update PHA. Requirements
reference to 29 CFR 1910.119 and 40 CFR	of 29 CFR 1910.119 and 40 CFR 68 do not
68.	apply to WTP, since there are no threshold
	chemicals present.
ISMP Section 12.0 Revise definition of	Revision is needed to conform to SRD

Safety Design Class. definition.	
----------------------------------	--

A. Evaluation.

Provision of Adequate Safety

Removal of the citations of 29 CFR 1910.119 and 40 CFR 68 as regulatory bases for the several safety criteria listed in the Tables above is being proposed because WTP does not contain the threshold quantities of chemicals that would trigger application of the programs required by these rules. Therefore these rules do not form the regulatory basis for the WTP's PSM program, or for the Risk Management Plan. This same rationale explains the changes proposed to SRD Section 9.3. The basis for the PSM program continues to be the requirements for the PSM program specified in DOE/RL-96-0006, Chapter 5. The revisions to the standards in the SRD do not affect the SRD's application of the correct regulatory basis document, and it is concluded these revisions do not affect the PSM program.

Replacement of cited sections of the ISMP with the SRD Appendix A as the implementing standard for safety criterion 1.0-1, 3.1-1, -2, -3, -4,- and -5, and 3.1-8 provides an implementing standard for these criterion that is more detailed. Additionally, the proposed new implementing standard more explicitly aligns the PSM program with the ISM process. Adoption of the new implementing standard does not affect the PSM program specified in the SRD other than to make the implementation details of certain elements of the program more clear.

Revision of the definition of "Safety Design Class" in SC's 1.0-8 and 2.0-2 is being proposed to bring the WTP PSM program more into line with commercial practice. The chemical industry currently does not recognise the term "Safety Design Class" (SDC). However both the industry and it's regulators (OSHA and EPA) do recognise the existence of a level of potential harm to workers and the public that warrants special consideration. Hence, for example, the PSM rule. Despite the fact that the PSM rule (per se) does not require implementation of a PSM program, WTP has elected to impose special design and operations requirements to chemicals that could conceivably pose undue risk to workers or to the public. This is done by applying the concept of "Safety Design Class" to structures, systems, and components (SSCs) used to protect workers and the public from significant chemical hazards. Application of the SDC category to WTP SSC's should, however, be comparable to levels of chemical hazards that, in commercial industry, represent a high level of concern. These levels of concern are proposed to be the ERPG-3 concentration at locations nearby the WTP (ie., at the co-located worker), ERPG-2 concentrations at locations more distant from the facility (ie., at the location of the public), or worker injury grave enough to trigger the emergency notification requirements of 29 CFR 1904.8 Reporting of fatality or multiple hospitalization incidents. By revising the definitions of SDC, the WTP is more consistent with commercial chemical industry practice, and continues to provide adequate safety to workers and the public. Several of the chemicals planned for use at WTP do not have published ERPG values. The DOE Subcommittee on Consequence Assessment and

Protective Action (SCAPA) has published Temporary Emergency Exposure Limits (TEELs) for chemicals that as yet do not have published ERPG values. The TEELs are equivalent to ERPG (eg., TEEL-3 = ERPG-3).

Revision of the requirement in SC 3.1-2 to collect all process safety information before conducting the PHA is proposed to enable better integration of the PSM program with the WTP overall ISM requirements. The purpose of ISM is to design in safety. Therefore, the Hazard Identification (or PHA) portion of ISM is often started using incomplete, or draft information. Some of the information required by SC 3.1-2 (e.g., analysis of consequences of deviation) is not available until after conducing the PHA. However, before the ISM process is completed, all of the information required by the SC 3.1-2 will have been developed. Therefore, the proposed revision does not affect the standard's ability to provide adequate safety.

Revision of the update interval for the Process Hazards Analysis (PHA) in SC 3.1-7 from the current 5 years to 1 year is proposed to provide better integration between the WTP's Radiological/Nuclear Safety and its PSM programs. Since the PHA scope includes both nuclear and chemical hazards, it makes sense to update both aspects at the same time. This change does not affect the ability of the standards to provide adequate safety.

Revision of the seismic design requirements specified in SC's 4.1-3 and 4.1-4 is proposed to make the design of the WTP, with respect to chemical hazards, consistent with commercial industry practice. Seismic Category I and II were developed to provide design requirements for SSC's needed to protect workers and the public from hazards not normally encountered in the chemical industry. These are the radiological hazards unique to (in this case) a nuclear waste processing plant. The chemical industry has proven seismic design requirements for SSC's needed to protect workers and the public from chemical hazards, many of which far exceed the chemical hazards at the WTP. These design requirements are contained in the Uniform Building Code. The UBC forms the basis for Seismic Category III. Therefore it is proposed the WTP adopt Seismic Category III as the governing standard for seismic design of SSC's related to chemical hazards. By revising the seismic design criteria in the SDC, the WTP is more consistent with commercial chemical industry practice, and continues to provide adequate safety to workers and the public.

Safety Criterion 4.3-7 has been revised to be consistent with the requirements of 29 CFR 1910.120, Hazardous Waste Operations and Emergency Response (HAZWOPER). This rule establishes maximum allowable concentrations of hazardous chemicals in the workplace under emergency conditions. These concentrations are equal to or less than ERPG-2 levels. Concentrations above these limits require personal protective equipment even for short term exposures. Therefore SC 4.3-7 continues to provide adequate safety.

The proposed revisions to Appendix A provide added clarity to the integration of PSM with the Radiological/Nuclear safety programs (Section 4.3.1), and bring the discussion of ERPG concentrations in Section 5.0 into line with the revisions proposed for SC 1.0-8 and 2.0-1. These revisions do not affect the standard's provision for adequate safety.

Compliance with applicable laws and regulations.

Laws and regulations potentially affected by the proposed changes to the SRD include 29 CFR 1910.119 and .120, 40 CFR 68, and the Uniform Building Code. WTP remains fully compliant with these laws and regulations.

Conformance to top-level safety standards.

The top-level safety standards applicable to the proposed changes to the SRD are those cited as regulatory bases in the various Safety Criteria proposed for revision in Table 1. Table 3 provides the title or subject of each top-level safety standard so cited, and a brief discussion showing that conformance to the standard is maintained.

Table 3. Conformance to Top-level Safety Standards DOE/RL-96-0006

	,	Standards DOE/RL-90-0000
Top-level standard	Safety Criterion	Statement of conformance
3.3.1 Public	1.0 - 8	The SRD remains unchanged w/r to this
Protection		top-level standard.
3.3.2 Worker	1.0 - 8	The approach proposed to evaluate the
Protection		design w/r to worker safety is consistent
		with acceptable industry practice, as
		evidenced in the discussion provided in the
		preceding sections of this evaluation.
3.3.3 Accident	3.1 - 4	The SRD remains unchanged w/r to this
Vulnerability		top-level standard. A new, more
Mitigation		comprehensive implementing standard is
		proposed.
4.1.2.3 Safety	7.8 - 2	The SRD remains unchanged w/r to this
Responsibility –		top-level standard.
Site and Technical		1
Support		
4.2.2.2 Proven	4.1 –3, -4	Substitution of the UBC seismic
Engineering	,	requirements for SSCs designed against
Practice -		chemical hazards is consistent with proven
		engineering practice, as evidenced by the
		discussion in the preceding sections of this
		evaluation.
4.2.4.1 Emergency	4.3 - 7	The SRD remains unchanged w/r to this
Preparedness –		top-level standard, in that the maximum
Support Facilities		allowable concentrations of hazardous
		chemicals in the control room under
		accident conditions remain at safe levels.
4.2.6.2 Human	4.3 - 7	The SRD remains unchanged w/r to this
Factors –		top-level standard, in that the maximum
Instrumentation		allowable concentrations of hazardous
Control and Design		chemicals in the control room under

		accident conditions remain at safe levels.
4.2.8.1	6.0 - 1	The SRD remains unchanged w/r to this
Preoperational		top-level standard.
Testing – Testing		
Program		
4.3.1.4 Conduct of	6.0 - 5	The SRD remains unchanged w/r to this
Operations -		top-level standard.
Readiness		
4.3.2.2 Radiation	7.2 - 5	The SRD remains unchanged w/r to this
Protection –		top-level standard.
Procedures and		
Monitoring		
4.3.3.1 Emergency	7.8 - 5	The SRD remains unchanged w/r to this
Preparedness –		top-level standard.
Offsite Measures		
4.3.4.1 Training and	7.2 - 3	The SRD remains unchanged w/r to this
Qualification –		top-level standard.
Personnel Training		
4.3.4.3 Training and	7.2 - 3	The SRD remains unchanged w/r to this
Qualification –		top-level standard.
Conditions Beyond		The state of the
the Design Basis		
4.3.5.1 Operational	7.6 – 2, -4	The SRD remains unchanged w/r to this
Testing, Inspection,	_,	top-level standard.
and Maintenance		
4.4.4 Unresolved	7.4 - 1	The SRD remains unchanged w/r to the
Safety Questions		radiological/nuclear safety aspects of this
		top-level standard. The safety criterion
		(7.4 - 1) has been revised to clarify it's
		applicability to chemical hazards as well.
5.1.1 Process Safety	1.0 - 1	The SRD remains unchanged w/r to its
Management		implementation of this top-level standard.
<i>J</i>		A new, more comprehensive implementing
		standard is proposed.
5.1.2 Process Safety	1.0 - 1	The SRD remains unchanged w/r to its
Objective		implementation of this top-level standard.
		A new, more comprehensive implementing
		standard is proposed.
5.2.1 Process Safety	3.1 - 2	The full suite of process safety information
Information		is still required, however the safety
		criterion has been modified to be more
		compatible with an emerging design and
		the cyclic nature of the ISM process. A
		new, more comprehensive implementing
		standard is proposed.
5.2.2 Process	3.1 – 1, -2, -3, -4, -	The SRD remains unchanged w/r to this
J.2.2 1 1000bb	[J.1 1, 2, J, ¬, ¬	The SIGN remains unchanged w/1 to this

Hazard Analysis	6, -7	top-level standard. A new, more
		comprehensive implementing standard is
		proposed.
5.2.3 Operating	7.2 - 5	The SRD remains unchanged w/r to this
Procedures		top-level standard.
5.2.4 Training	7.2 - 3	The SRD remains unchanged w/r to this
		top-level standard.
5.2.5 Subcontractors	7.1 - 2	The SRD remains unchanged w/r to this
		top-level standard.
5.2.6 Pre-startup	6.0 - 5	The SRD remains unchanged w/r to this
Safety Review		top-level standard.
5.2.7 Mechanical	7.6 - 4	The SRD remains unchanged w/r to this
Integrity		top-level standard.
5.2.8 Hot Work	4.5 - 23	The SRD remains unchanged w/r to this
Control		top-level standard.
5.2.9 Management	4.0 – 2, 7.4 - 1	The SRD remains unchanged w/r to the
of Change		radiological/nuclear safety aspects of this
		top-level standard. The safety criterion
		(7.4 - 1) has been revised to clarify it's
		applicability to chemical hazards as well.
5.2.10 Incident	7.7 - 1, -2, -3	The SRD remains unchanged w/r to this
Investigation		top-level standard.
5.2.11 Emergency	7.8 - 2	The SRD remains unchanged w/r to this
Planning and		top-level standard.
Response		
5.2.12 Compliance	7.3 - 10	The SRD remains unchanged w/r to this
Audits		top-level standard.

B. Certification of SRD Changes

The SRD continues to identify a set of standards that, when implemented, will provide adequate safety, comply with all applicable laws and regulations, and conform to top-level safety standards.

Certification that the revised SRD identifies a set of standards that continues to provide adequate safety, comply with all applicable laws and regulations, and conform to top-level safety standards is based on adherence to the DOE/RL-96-0004 Standards Identification Process and successful completion of review and confirmation by the PSC.

WTP General Manager/Designee – Approval	Date